

Laboratory Analysis SOC + B-VIAL RETAKE								
Order Number	Lab Id	Matrix	Location	Date Collected	Time Collected	Collected By	Description	Status
2021084069	P0821-658	Drinking Water		8/26/2021	8:00	TB		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date		
Hexachlorobenzene	<0.1	ug/L	HW	0.1	EPA 508.1	9/9/2021		
Lindane	<0.1	ug/L	HW	0.1	EPA 508.1	9/9/2021		
Heptachlor	<0.2	ug/L	HW	0.2	EPA 508.1	9/9/2021		
Heptachlor Epoxide	<0.1	ug/L	HW	0.1	EPA 508.1	9/9/2021		
Chlordane (alpha & gamma)	<0.05	ug/L	HW	0.1	EPA 508.1	9/9/2021		
Endrin	<0.1	ug/L	HW	0.1	EPA 508.1	9/9/2021		
Toxaphene	<1.0	ug/L	HW	1.0	EPA 508.1	9/9/2021		
SOC C-SPE Extraction	DONE		TRS		EPA 508.1	8/31/2021		
Dalapon	<5	ug/L	SPH	5	EPA 552.2	9/8/2021		
Dalapon-LL Extraction	DONE		SPH		EPA 552.2	9/7/2021		
1,2-Dibromo-3-ChloropropaneDBCP	<0.02	ug/L	HW	0.02	EPA 504.1	9/4/2021		
Ethylene Dibromide (EDB)	<10.0	ng/L	HW	10.0	EPA 504.1	9/4/2021		
SOC F-LL Extraction	DONE		HW		EPA 504.1	9/4/2021		
Diquat	<2.0	ug/l	HW	2.0	EPA 549.2	9/7/2021		
SOC H-SPE Extraction	DONE		TRS		EPA 549.2	8/27/2021		
Endothall	<9	ug/l	HW	9	EPA 548.1	9/7/2021		
SOC I-SPE Extraction	DONE		TRS		EPA 548.1	8/27/2021		
Carbofuran	<0.9	ug/l	FO	0.9	EPA 531.2	9/30/2021		
Oxamyl (Vydate)	<1.0	ug/l	FO	1.0	EPA 531.2	9/30/2021		
SOC B Sample Filtration	DONE		FO		EPA 531.2	9/27/2021		
2,4,5-TP	<1	ug/l	HW	1	EPA 515.2	10/4/2021		
2,4-D	<1	ug/l	HW	1	EPA 515.2	10/4/2021		
Dinoseb	<1	ug/l	HW	1	EPA 515.2	10/4/2021		
Pentachlorophenol	<0.4	ug/l	HW	0.4	EPA 515.2	10/4/2021		
Picloram (Tordon)	<1	ug/L	HW	1	EPA 515.2	10/4/2021		
SOC E-SPE Extraction	DONE		TRS		EPA 515.2	9/30/2021		
Comments: Eurofins at South Bend, IN (C-71-01) handles this analysis and CMDP submission.								

Laboratory Analysis SOC-AG&D-RETAKE								
Order Number	Lab Id	Matrix	Location	Date Collected	Time Collected	Collected By	Description	Status
2021112915	P1121-356	Drinking Water		11/18/2021	09:00			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date		
Benzo(a)pyrene	<0.1	ug/L	HW	0.1	EPA 525.2	12/2/2021		
Alachlor (Lasso)	<0.2	ug/L	HW	0.2	EPA 525.2	12/2/2021		
Atrazine	<0.2	ug/L	HW	0.2	EPA 525.2	12/2/2021		
Di(2-ethylhexyl)adipate	<0.6	ug/L	HW	0.6	EPA 525.2	12/2/2021		
Di(2-ethylhexyl)phthalate	<0.6	ug/L	HW	0.6	EPA 525.2	12/2/2021		
Hexachlorocyclopentadiene	<0.5	ug/L	HW	0.5	EPA 525.2	12/2/2021		
Methoxychlor	<0.1	ug/L	HW	0.1	EPA 525.2	12/2/2021		
Simazine	<0.2	ug/L	HW	0.2	EPA 525.2	12/2/2021		
SOC AG-SPE Extraction	DONE	ug/L	HW		EPA 525.2	11/23/2021		

Laboratory Analysis LEAD & COPPER								
Order Number	Lab Id	Matrix	Location	Date Collected	Time Collected	Collected By	Description	Status
2021083901	C0821-160	Drinking Water	407 Liberty St	8/21/2021	9:00	TB		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date		
Lead, Total Rec.-(ICP/MS)	<1.0	ug/L	SPH	1.0	EPA 200.8	9/1/2021		
Copper, Total Rec.-(ICP/MS)	0.015	mg/L	SPH	0.002	EPA 200.8	9/1/2021		

Laboratory Analysis TTHM/HAA5								
Order Number	Lab Id	Matrix	Location	Date Collected	Time Collected	Collected By	Description	Status
2021092212	P0921-211	Drinking Water	707 Hwy 56	9/14/2021	7:30	TB		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date		
HAA5	<1.0	ug/L	SPH	1.0	EPA 552.2	9/21/2021		
Order Number	Lab Id	Matrix	Location	Date Collected	Time Collected	Collected By	Description	Status
2021092212	P0921-208	Drinking Water	723 E. Main St	9/14/2021	8:00	TB		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date		
Total THM	13.5	ug/L	SPH	0.5	EPA 524.2	9/16/2021		
Order Number	Lab Id	Matrix	Location	Date Collected	Time Collected	Collected By	Description	Status
2021092212	P0921-209	Drinking Water	725 E. Main St	9/14/2021	8:00	TB		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date		
HAA5	4.78	ug/L	SPH	1.0	EPA 552.2	9/21/2021		
Order Number	Lab Id	Matrix	Location	Date Collected	Time Collected	Collected By	Description	Status
2021092212	P0921-210	Drinking Water	707 Hwy 56	9/14/2021	7:30	TB		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date		
TOTAL THM	1.26	ug/L	SPH	0.5	EPA 524.2	9/16/2021		